Emergency Response Guide

# SolarEdge Home Battery 48V, 48V (W) and Three-Phase

Version 1.0

November 2025

MAN-01-01295-1.0

# Table Of Contents


Revision history ..... 1

About ..... 1

- Overview ..... 1
  - Rechargeable lithium-ion batteries: SolarEdge products ..... 1
- Identification of products and company ..... 2

Handling and use precautions and identification of hazards ..... 4

- High voltage hazard ..... 5
- Hazards associated with mechanical damage ..... 5
- Hazards associated with elevated temperature exposure ..... 5
- Hazards associated with a leaked electrolyte ..... 6
- Hazards Associated with Vented Electrolyte ..... 6
- Firefighting measures ..... 7
- First aid measures ..... 8
- Storage precautions for safe handling ..... 9
  - Conditions for safe storage ..... 9
- Storage conditions and temperature ..... 9
- Installation precautions ..... 9
- Handling, storage, and transportation of a damaged SolarEdge Home Battery ..... 10
- Disposal procedures ..... 10
- Maintenance or repair ..... 11
- Transport information ..... 11
- Flooding measures ..... 11

Regional emergency phone numbers ..... 12


© SolarEdge Technologies, Ltd 2025. All rights reserved.

# Revision history

| Version | Date | Description |
|---|---|---|
| 1.0 | November 2025 | Initial version |

# About

This document applies to the following products:

- SolarEdge home battery - 48V
- SolarEdge home battery - 48V (W)
- SolarEdge home battery - Three Phase

## Overview

### Rechargeable lithium-ion batteries: SolarEdge products

The products referenced herein are exempt articles and are not subject to OSHA's Hazard Communication Standard requirements for preparation of Safety Data Sheets (SDS).

Relevant PNs: **BAT-05K48M0W-XX** and **BAT-05K48M0B-XX**.

## SDS

Safety Data Sheets (SDS) are a sub-requirement of the Occupational Safety and Health Administration (OSHA) Hazard Communication Standard, 29 CFR Subpart 1910.1200. This Hazard Communication Standard does not apply to various subcategories including anything defined by OSHA as an “article.” OSHA has defined “article” as a manufactured item other than a fluid or particle; (i) which is formed to a specific shape or design during manufacture; (ii) which has end use function(s) dependent in whole or in part upon its shape or design during enduse; and (iii) which under normal conditions of use does not release more than very small quantities (e.g., minute or trace amounts) of a hazardous chemical, and does not pose a physical hazard or health risk to employees.

## USA

SolarEdge Home Battery products meet the OSHA definition of “article.” Therefore, they are exempt from the requirements of the Hazardous Communication Standard and an SDS is not required.

## EU

The products are not “substances” or “mixtures” according to Regulation (EC) No 1907/2006 EC. Instead they have to be regarded as “articles”. No substances are intended to be released during handling. Therefore, there is no obligation to supply a Safety Data Sheet according to Regulation (EC) 1907/2006, Article 31.

© SolarEdge Technologies, Ltd 2025. All rights reserved.

## Identification of products and company

| Product | Rechargeable lithium-ion SolarEdge Home Battery for use with SolarEdge inverters and modules and sub-assemblies that can be installed in the SolarEdge Home Battery. Specific part numbers are listed below. | |
|---|---|---|
| | USA | 47505 Seabridge Drive, Fremont, CA, 94538<br><br>+1.510.353.1895 |
| Locations | Europe | Werner-Eckert-Str.6 81829 Munich<br><br>+49.(0)89.454.5970 |
| | | Suite 10, 23-25 Gipps Street, Collingwood, VIC |
| | Australia | 3066 |
| | | +61 1800 465 567 |
| Emergency Contacts | CHEMTREC | For Hazardous Materials [or Dangerous Good] Incidents: Spikk, Leak, Fire, Exposure or Accident Call CHEMTREC Day or Night.<br><br>USA:<br><br>Europe and Australia: |
| Emergency Telephone Numbers | Inside United States Territories and Canada: | 1-800-424-9300 |
| | Inside Europe: | See Regional Emergency Phone Numbers |
| | Outside United States Territories, Canada, and<br><br>Europe | See Regional Emergency Phone Numbers |

SolarEdge Home Battery contains battery subassemblies made up of rechargeable lithium-ion cells. SolarEdge Home Battery and its respective battery subassemblies are covered by this document.

SolarEdge Home Battery contains sealed lithium-ion battery cells that are similar to rechargeable batteries in many consumer electronic products. Cells are individually, hermetically sealed prisms (prismatic cells). Each of these cells contain lithium-ion electrodes and electrolyte (the approximate composition is listed below). THE CELLS AND BATTERIES DO NOT CONTAIN METALLIC LITHIUM. Individual cells have nominal voltages of approximately 3.6 V.

© SolarEdge Technologies, Ltd 2025. All rights reserved.

| Composition and Information on ingredients for SolarEdge Home Battery 48V and Three Phase | | |
|---|---|---|
| Hazardous Ingredients (Chemical Name) | Concentration or concentration ranges (%) | CAS Number |
| Ferrous Phosphate Lithium | 27.04 | 15365-14-7 |
| Ferrum | 23.52 | 7439-89-6 |
| Organic solvent | 13.44 | - |
| Graphite | 12.78 | 7782-42-5 |
| Copper | 9.22 | 7440-50-8 |
| Aluminium | 6.44 | 7429-90-5 |
| Polyethylene | 4.37 | 9002-88-4 |
| Lithium Hexafluorophosphate | 2.01 | 21324-40-3 |
| Nickel | 1.18 | 14332-32-2 |

| Attribute | Value | Unit |
|---|---|---|
| Model name | BAT-05K48-01 | - |
| Description | SolarEdge Home Battery, 48V and Three Phase | - |
| Shipped Voltage | 48 | $V_{dc}$ |
| Installed Voltage (Min – Nom – Max) | (44.8-48-56.5) | $V_{dc}$ |
| Weight | 120.6 / 54.7 | lb / kg |
| Dimensions (W x H x D) | 21.3 x 19.7 x 9.4 / 540 x 500 x 240 | In / mm |

| Composition and information on ingredients for the SolarEdge Home Battery 48V (W) | | | | |
|---|---|---|---|---|
| Common Chemical Name | Chemical Formula | Concentration (%) | CAS No. | EC No. |
| Lithium iron phosphate | LiFePO4 | 49 | 15365-14-7 | 476-700-9 |
| Polypropylene | $C_3H_6$ | 5 | 9002-88-4 | 200-815-3 |
| Aluminum foil | Al | 6 | 7429-90-5 | 231-072-3 |
| Copper foil | Cu | 13 | 7440-50-8 | 231-159-6 |

© SolarEdge Technologies, Ltd 2025. All rights reserved.


| Composition and information on ingredients for the SolarEdge Home Battery 48V (W) | | | | |
|---|---|---|---|---|
| Lithium hexafluorophosphate | LiPF6 | 3 | 21324-40-3 | 244-334-7 |
| Graphite | C | 24 | 7782-42-5 | 231-955-3 |

| Attribute | Value | Unit |
|---|---|---|
| Model name | BAT-05K48-01 | - |
| Description | SolarEdge Home Battery, 48V (W) | - |
| Shipped Voltage | 48 | $V_{dc}$ |
| Installed Voltage (Min – Nom – Max) | (44.8-48-56.5) | $V_{dc}$ |
| Weight | 50.5 | kg |
| Dimensions (W x H x D) | 725 x 370 x 245 | mm |

## Handling and use precautions and identification of hazards

The products described by this document are dangerous if mishandled. Injury to property or person, including loss of life, is possible if mishandled.

SolarEdge Home Battery contains lithium-ion cells. A cell is a source of energy. Do not short circuit, puncture, incinerate, crush, immerse, force discharge or expose to temperatures above the product's stated operating temperature (Hazards associated with elevated temperature exposure [5]) . An internal or external short circuit can cause significant overheating and provide an ignition source, resulting in fire, including surrounding materials or materials within the cell or battery. The electrode materials and electrolyte they contain are not exposed while under normal conditions of use, as long as the battery integrity is maintained, and seals remain intact. Risk of exposure may occur only in cases of mistreatment, be that mechanical, thermal, or electrical.




© SolarEdge Technologies, Ltd 2025. All rights reserved.

## High voltage hazard

Correct handling of the product does not pose an electrical hazard under normal conditions of use, provided that the SolarEdge Home Battery's enclosure remains closed. All of the constituent component battery cells are arranged inside a plastic structure and sealed within the Battery in a metal enclosure.

If the outer enclosure, Pod enclosures, and/or safety circuits are compromised or have been significantly damaged then a SolarEdge Home Battery may present a significant high voltage and risk of electrocution. A battery pack, even in a normally discharged condition is likely to contain substantial electrical charge and can cause injury or death if mishandled. If a SolarEdge Home Battery has been significantly visibly damaged or its enclosure compromised, then practice appropriate high-voltage preventative measures until the danger has been assessed and dispersed if required.

**WARNING**

Never cut into a sealed SolarEdge Home Battery enclosure due to the high voltage and electrocution risks.

For detailed installation/removal instructions, refer to the SolarEdge Home Battery installation manual.

## Hazards associated with mechanical damage

Mechanical damage to a SolarEdge Home Battery can result in several hazardous conditions including:

- Leaked cell electrolyte, refer to Hazards associated with leaked electrolytes [6]).
- Rapid heating of individual cells due to exothermic reaction of constituent materials (cell thermal runaway), venting of cells, and propagation of self-heating, and thermal runaway reactions to neighboring cells.
- Fire

To avoid mechanical damage to a SolarEdge Home Battery, items should be stored in their original packaging when not being used or before being installed, refer to Storage precautions [9].

## Hazards associated with elevated temperature exposure

The SolarEdge Home Battery is designed to endure operating temperatures up to 50°C (122°F), with up to 100% operating humidity (condensing), and storage temperatures up to 60°C (140°F) and <95% relative humidity (non-condensing) for up to 24 hours.

Exposure of SolarEdge Home Battery to high temperatures can drive battery cells into thermal runaway and result in a fire.

- Storage for more than 24 hours at temperatures above approximately 80°C (176°F) could result in cell thermal runaway reactions and should be avoided.

© SolarEdge Technologies, Ltd 2025. All rights reserved.

- Storage for more than a few minutes at temperatures above approximately 150°C (302°F) could result in cell thermal runaway reactions and should be avoided.

Exposure of a SolarEdge Home Battery to localized heat sources such as flames could result in cell thermal runaway reactions and should be avoided.

## Hazards associated with a leaked electrolyte

The electrolyte within constituent cells includes a volatile hydrocarbon-based liquid and a dissolved lithium salt such as lithium hexafluorophosphate which acts as the source of lithium ions. The electrolyte is mostly absorbed in electrodes within individual sealed cells. Under normal conditions of use no one handling the SolarEdge Home Battery should contact the electrolyte.

Mechanical damage, such as severe crushing, can cause a small amount of electrolyte to leak out of a cell.

Electrolytes can be extracted from a single cell using a centrifuge, or under some extreme conditions of abuse, such as a crush.

Any released electrolyte liquid is likely to quickly evaporate, leaving behind a white salt residue. Evaporated electrolyte is flammable and contains alkyl-carbonate compounds. Leaked electrolyte is colorless and characterized by a sweet odor. If such an odor is obvious, evacuate or clear the surrounding area and ventilate the area.

**WARNING**

Avoid contact with with electrolytes.

Leaked electrolyte solution is flammable and corrosive and can act as an irritant to the eyes and skin. If a liquid is observed that is suspected of being an electrolyte, ventilate the area and avoid contact with the liquid until a positive identification can be made and adequate protective equipment can be obtained (eye, skin, and respiratory protection). Chemical classifier strips can be used to identify the spilled liquid (electrolyte will contain petroleum/organic solvent and fluoride compounds).

For an electrolyte leak, the following protective equipment is recommended: an air purifying respirator with organic vapor/acid gas cartridges, safety goggles or a full face respirator,and safety gloves (Butyl rubber or laminated film (e.g., Silver Shield)). Protective clothing should be worn. Use a dry absorbent material to clean up a spill.

## Hazards Associated with Vented Electrolyte

Lithium-ion cells are sealed units, and thus under proper usage and normal conditions, venting of electrolyte should not occur. If lithium-ion cells are subjected to abnormal heating or other conditions of abuse, electrolyte and electrolyte decomposition products can vaporize and be vented from cells. Vented gases are a common early indicator of a thermal runaway reaction – an abnormal and hazardous condition.

If gases or smoke are observed escaping from a SolarEdge Home Battery, evacuate the area and notify a first responder team and/or the local fire department. Gases or smoke exiting a lithium-ion battery pack are likely flammable and could ignite unexpectedly as the condition

© SolarEdge Technologies, Ltd 2025. All rights reserved.

that led to cell venting may also cause ignition of the vent gases. A venting SolarEdge Home Battery should only be approached with extreme caution by trained first responders equipped with appropriate personal protective equipment (PPE), as discussed in Firefighting measures [7].

The composition of cell vent gas depends on several factors, including cell composition, cell state of charge, and the cause of cell venting. Vent gases may include volatile organic compounds (VOCs) such as alkyl-carbonates, methane, ethylene, and ethane; hydrogen gas; carbon dioxide; carbon monoxide; soot; and particulates containing oxides of nickel, aluminum, lithium, copper, and cobalt. Additionally, phosphorus pentafluoride, POF3, and HF vapors may form.



**WARNING**

Avoid contact with vented gases.

Vented gases may irritate the skin, eyes, and throat. Cell vent gases are normally hot; upon exit from a cell, vent gas temperatures can exceed 600°C (1,110°F). Contact with hot gases can cause thermal burns. Vented electrolyte is flammable and may ignite on contact with a source of ignition such as an open flame, spark, or a sufficiently heated surface.

Vented electrolytes may also ignite on contact with cells undergoing a thermal runaway reaction.

## Firefighting measures

Responding to a Venting SolarEdge Home Battery: Smoke venting from a SolarEdge Home Battery is an indication of an abnormal and hazardous condition. Smoke is the most obvious first sign of a thermal runaway event, though other signs include loud banging sounds heard from the SolarEdge Home Battery or heat emanating from the SolarEdge Home Battery. Any smoke venting from the SolarEdge Home Battery is probably flammable and may ignite at any time. If fire or smoke is seen being expelled from a SolarEdge Home Battery at any time, the following should be performed:

1. If possible, turn off the unit/system.
2. Evacuate the area.
3. Inform suitably trained first responders and the local fire department that there is a potential chemical fire involving Li-Ion cells.

The SolarEdge Home Battery should then be monitored for evidence of continued venting of smoke. Spraying with high volumes of water from a safe distance may help cool the unit and prevent further reaction or a fire from developing. In public agencies, an Incident Command System is used to manage emergencies as defined by FEMA (Federal Emergency Management Agency). Where an Incident Command System is in place, if a fire erupts and visible flames appear, the Incident Commander should determine whether an attempt will be made to suppress the fire (aggressive firefighting) or allow the battery to burn until it self-extinguishes, while protecting surrounding materials (defensive firefighting).

© SolarEdge Technologies, Ltd 2025. All rights reserved.

SolarEdge recommends that large volumes of water be used from a safe distance to fight a fire involving a SolarEdge Home Battery. Water will suppress flames and can cool cells, limiting propagation of thermal runaway reactions.

However, if water is used, electrolysis of water (splitting of water into hydrogen and oxygen) may contribute to the flammable gas mixture formed by venting cells, burning plastic, and burning of other combustibles.

Gaseous agents such as CO2 or Halon, or dry chemical suppressants may temporarily suppress flaming of lithium-ion battery packs, but they will not cool lithium-ion batteries and will not limit the propagation of cell thermal runaway reactions. Metal fire suppressants such as LITH-X, graphite powder, or copper powder are not suitable substances for suppressing fires involving lithium-ion battery packs as they are unlikely to be effective.

A battery fire may continue for several hours and it may take 24 hours or more for the battery pack to cool. Lithium-ion battery fires that have been extinguished can re-ignite due to the exothermic reaction of constituent materials from broken or damaged cells. To prevent this, remove sources of ignition and cool the burned mass by flooding with water.

**Aggressive Firefighting**: If a decision is made to aggressively fight a fire involving a SolarEdge Home Battery, then copious amounts of water should be applied from a safe distance. The water may not suppress all cell thermal runaway reactions within the battery pack, but it may cool cells and control the spread of the fire.

**Defensive Firefighting**: Having decided to fight a SolarEdge Home Battery fire defensively, then the fire crew should retreat a safe distance and allow the battery to burn itself out. Fire crews may choose to use a water stream or fog pattern to protect exposures or control the path of smoke. A battery fire may continue for several hours and may result in multiple re-ignition events. It may take 24 hours or longer for the battery pack to cool.

**Firefighter PPE**. Firefighters should wear self-contained breathing apparatus (SCBA) and fire protective turnout gear. Cells or batteries may flame or leak potentially hazardous organic vapors if exposed to excessive heat, fire, or overvoltage conditions. These vapors may include volatile organic compounds (VOCs), hydrogen gas, carbon dioxide, carbon monoxide, soot, and particulates containing oxides of nickel, aluminum, lithium, copper, and cobalt. Additionally, phosphorus pentafluoride, POF3, and HF vapors may form.

## First aid measures

**Electric Shock / Electrocution**: Get immediate medical aid if an electrical shock or electrocution has occurred or is suspected.

**Contact with Leaked Electrolyte**: The constituent battery cells are sealed. The content of an open or broken constituent battery cell can cause skin irritation and/or chemical burns. If materials from a ruptured or otherwise damaged cell or battery contact the skin, flush immediately with water and wash the affected area with soap and water. If a chemical burn occurs or if irritation continues, get medical assistance.

For eye contact, flush with large amounts of water for 15 minutes without rubbing and see a doctor immediately.

© SolarEdge Technologies, Ltd 2025. All rights reserved. 

**Inhalation of Electrolyte Vapors**: If electrolyte vapors are inhaled, move person into fresh air. If the person has stopped breathing administer artificial respiration. Get immediate medical assistance.

**Vent Gas Inhalation**: If vent gases are inhaled, move person into fresh air. If the person has stopped breathing administer artificial respiration. Get immediate medical assistance.

## Storage precautions for safe handling

- Avoid mechanical damage of the residential energy system. Do not open or disassemble the residential energy system.
- Avoid short circuiting the cell. Remove jewelry items such as rings, wristwatches, pendants, etc. that could contact the battery terminals if the terminals are exposed.
- Keep away from open flames, hot surfaces, and sources of ignition.

### Conditions for safe storage

Store residential energy storage under the following conditions when not in use:

- Store in a protected battery warehouse area on pallets or similar devices to enable any leaks to be visibly observed upon inspection and to ensure the items do not come into contact with water or a salty breeze.
- Store away from heat sources, such as furnaces, open flames, etc.
- Keep in the closed original container.
- Store in an upright position and in areas that are not likely to be damaged or disturbed by personnel, equipment, or vehicles.
- Do not store unboxed items in areas with a source of spark generation within 30 cm, in direct sunlight, in direct exposure to exhaust gases, such as from automobiles, or in places with continuous or intermittent vibration.

## Storage conditions and temperature

| Storage Duration* | Allowable Temperature Range |
|---|---|
| 12 months | -10°C - 45°C |

*From the production date

If the product has been stored for more than 12 months in its original package, DO NOT ship it before contacting the SolarEdge support team for technical guidelines.

## Installation precautions

Elevated temperatures can result in a hazardous condition.

Make sure the installation location doesn't exceed the battery Operating temperature range between -10°C and 50°C. Installation in areas where temperatures routinely approach or

© SolarEdge Technologies, Ltd 2025. All rights reserved.

exceed 80°C (176°F) could result in a hazardous condition. Do not install the battery near heating equipment.

The installation location should be protected from the risk of flooding. If the battery is installed in an area below the floodplain, where flooding can occur, flood prevention should be implemented to prevent more than 30cm of standing water for a maximum of 30 minutes.

Installation locations should follow local fire code requirements and the instructions and warnings in the installation guide.

## Handling, storage, and transportation of a damaged SolarEdge Home Battery

If a SolarEdge Home Battery has been damaged (battery enclosure has been dented or compromised), it is possible that heating is occurring that may eventually lead to a fire. Damaged or opened cells/batteries can result in rapid heating (due to exothermic reactions of the constituent materials), the release of flammable vapors, and propagation of self-heating and thermal runaway reactions to neighboring cells.

Before handling or transporting a damaged SolarEdge Home Battery, wait at least one hour. Smoke may indicate that a thermal reaction is in progress. If no smoke, flame, leakage of electrolyte, leakage of coolant, or any other signs of heat has been observed for one hour, the SolarEdge Home Battery may be disconnected and moved into a safe location. To obtain specific instructions for evaluating, disconnecting, and preparing a damaged SolarEdge Home Battery for transport, please contact the SolarEdge Service team.

A damaged SolarEdge Home Battery should be monitored during storage for evidence of smoke, flame, leakage of electrolyte, leakage of coolant, or signs of heat. If the Product cannot be monitored full-time, for example during extended storage, the Product should be moved to a safe storage location.

Safe storage locations for damaged batteries must be free of flammable materials, accessible only by trained professionals, and 50 feet downwind of occupied structures. For example, a fenced, open yard may be an appropriate safe location.

DO NOT STORE DAMAGED SolarEdge Home Battery ADJACENT TO UNDAMAGED SolarEdge Home Battery.

A damaged battery may suffer further damage during transportation and may lead to a fire. To further reduce this risk, handle the damaged battery with extreme caution.

## Disposal procedures

SolarEdge Home Battery batteries do not contain heavy metals such as lead, cadmium, or mercury.

Disposal of or recycling of SolarEdge Home Battery should conform to local, state, and federal regulations. Note that regulations regarding disposal of batteries vary by jurisdiction.

If disposing of the SolarEdge Home Battery without return to SolarEdge, please consult with local, state and/or federal authorities as to suitable methods of disposal and recycling.

© SolarEdge Technologies, Ltd 2025. All rights reserved.

## Maintenance or repair

The Battery and its components are not user serviceable.

Do not attempt to open, disassemble, repair, tamper with, or modify the Battery. The Battery cells are not replaceable. Contact SolarEdge Support for guidance on repairs.

## Transport information

Lithium-ion batteries are regulated as Class 9 Miscellaneous dangerous goods (also known as “hazardous materials”) pursuant to the International Civil Aviation Organization (ICAO) Technical Instructions for the Safe Transport of Dangerous Goods by Air, International Air Transport Association (IATA) Dangerous Goods Regulations, the International Maritime Dangerous Goods (IMDG) Code, European Agreements concerning the International Carriage of Dangerous Goods by Rail (RID) and Road (ADR), and applicable national regulations such as the USA’s hazardous materials regulations (see 49 CFR 173.185) or similar local regulations as applicable. These regulations contain very specific packaging, labeling, marking, and documentation requirements. The regulations also require that individuals involved in the preparation of dangerous goods for transport be trained on how to properly package, label, mark and prepare shipping documents.

| | |
|---|---|
| UN Number | 3480 |
| Proper Shipping Name | Lithium Ion Batteries |
| Hazard Classification | Class 9 Miscellaneous |
| Packing Group | N/A |

## Flooding measures

The battery must be installed in places that are protected from flooding. To maintain the battery warranty it is essential that the battery is not exposed to flooding.

**WARNING**

If flooding happens, it is dangerous to keep using the battery. Take the following measures:

1. Turn OFF the circuit breaker and the soft switch of the battery.
2. Disconnect the battery cables from the battery and the Inverter.
3. Do not move or disassemble the battery.
4. Try to remove the standing water from the battery location as much as you can.
5. Call SolarEdge support for further instructions.

© SolarEdge Technologies, Ltd 2025. All rights reserved.

# Regional emergency phone numbers

| Country | Local Number | Toll-Free Number |
|---|---|---|
| Australia | +61 2 9037 2994 | 1800 862 115 |
| Austria | +43 1 3649237 | 0800 293702 |
| Belgium | +32 2 808 32 37 | |
| Canada | +1 703-741-5970 | 1-800-424-9300 |
| Czech Republic | +420 228 880 039 | |
| Denmark | +45 69 91 85 73 | |
| Finland | +358 9 42419014 | |
| France | +33 9 75 18 14 07 | |
| Germany | +49 69 643508409 | 0800 1817059 |
| Greece | +30 21 1176 8478 | |
| Hungary | +36 1 808 8425 | |
| Iceland | +354 539 0655 | |
| Ireland | +353 1 901 4670 | |
| Israel | +972 3-763-0639 | |
| Italy | +39 02 4555 7031 | 800 789 767 |
| Latvia | +371 66 165 504 | |
| Lithuania | +370 5 214 0238 | |
| Luxembourg | +352 20 20 24 16 | |
| Macedonia | +389 2 551 7456 | |
| Mexico | | 800 681 9531 |
| Netherlands | +31 85 888 0596 | |
| New Zealand | +64 9-801 0034 | 0800 425 459 |
| Panama | +507 832-2475 | |
| Poland | +48 22 398 80 29 | |
| Portugal | +351 308 801 773 | |

© SolarEdge Technologies, Ltd 2025. All rights reserved.

| Country | Local Number | Toll-Free Number |
|---|---|---|
| Romania | +40 376 300 026 | |
| Russia | | 8 (800) 100-63-46 |
| Singapore | +65 3158 1349 | 800 101 2201 |
| Slovakia | +421 2/330 579 72 | |
| Slovenia | +386 1 888 80 16 | |
| South Africa | | 080 098 3611 |
| South Korea | | 080 822 1374 |
| Spain | | 900 868 538 |
| Sweden | +46 8 525 034 03 | |
| Taiwan | +886 2 7741 4207 | 00801-14-8954 |
| Ukraine | +380 94 710 1374 | |
| United Kingdom | +44 20 3807 3798 | |
| United States | +1 703-741-5970 | 1-800-424-9300 |

© SolarEdge Technologies, Ltd 2025. All rights reserved.